



Clarence-Rockland

**CORPORATION
de la Cité de/ of the City of
CLARENCE-ROCKLAND**

ADDENDUM #2

10/05/2018 8:21

F18-INF-2018-013

Tender Number

WM Replacement

Request for Proposals Issued On:

26-Apr

Proposal Submission Deadline: 2:00:00pm Local Time in Clarence-Rockland Ontario, Canada on

18-May-18

THE INFORMATION CONTAINED IN THIS DOCUMENT IS TIME SENSITIVE

Please note: This addendum is to be considered part of the above noted Request for Proposal/Tender as though included with the original version. This addendum does not affect the closing date/time: Bidders should acknowledge receipt of all Addendum / Addenda by inserting in the space provided on the Bid Submission Form, the numbers of all Addendum / Addenda received during the bidding period.

QUESTION REQUESTING CLARIFICATION

The following questions were received:

1	Question:	Does the City require drawings to be prepared for the rehabilitation scope on Laurier Street East and West or can this be tendered with specifications only?
	Reply:	All tenders documents include Specifications and Drawings, one package per street.
2	Question:	The "Laurier Street Revitalization" RFP (F18-INF-2018-024) posted on May 4th, 2018 states that a recently completed topographic survey will be given to the Consultant. Please advise whether this survey will be made available for watermain design on Laurier
	Reply:	The existing topographic survey "Laurier Street Revitalization" is out of the limits of the RFP F18-INF-2018-013 project.
3	Question:	Does the City require topographic survey to be completed for the street rehabilitation scope on Laurier Street East and West?
	Reply:	Yes, inside the right of way.
4	Question:	Please advise the diameter of the watermains to be replaced.
	Reply:	Please see attached sketch.
5	Question:	Is any analysis of watermain hydraulic capacity required, or can watermains be replaced on a like-for-like basis (respecting minimum diameter requirements and any requirements of the City's Water Master Plan)?
	Reply:	Same as the existing diameter.
6	Question:	Can you confirm if the entire road is to be rehabilitated on Gareau and Pouliotte?
	Reply:	Yes.
7	Question:	Is so, is the scope limited to watermain replacement and road replacement including base/granulars?
	Reply:	Yes
8	Question:	Confirm there is no sanitary or storm sewer renewal even if the watermain and road are being replaced?
	Reply:	Yes
9	Question:	Confirm the where there is a watermain replacement, but no road rehabilitation, the road reinstatement is limited to trench reinstatement?
	Reply:	Road rehabilitation at the watermain replacement area.