



Clarence-Rockland
CORPORATION
de la Cité de/ of the City of
CLARENCE-ROCKLAND

ADDENDUM #1

20/02/2018 9:37

F18-INF-2018-005

Tender Number

Replacement of Three Culverts

Request for Proposals Issued On:

12-Feb

Proposal Submission Deadline: 2:00:00pm Local Time in Clarence-Rockland Ontario, Canada on

13-Mar-17

THE INFORMATION CONTAINED IN THIS DOCUMENT IS TIME SENSITIVE

Please note: This addendum is to be considered part of the above noted Request for PTender as though included with the original version. This addendum does not affect the closing date/time: Bidders should acknowledge receipt of all Addendum / Addenda by inserting in the space provided on the Bid Submission Form, the numbers of all Addendum / Addenda received during the bidding period.

QUESTION REQUESTING CLARIFICATION

The following questions were received:

1	Question:	Can we use welded wire mesh Grade 500 instead of Grade 400 rebar to reinforce the box culverts? If wire mesh is approved, can we use a cover of 50 mm +/- 10mm?
	Reply:	The proposed substitutions are acceptable provided CHBDC 2014 requirements are met.