



THE CORPORATION OF THE CITY OF CLARENCE-ROCKLAND

ADDENDUM #2

DATE: March 15, 2017

Tender Number

F18-PS-2017-001

Project Management Services-Fire Hall

Request for Proposals Issued On: 22-Feb-17

Proposal Submission Deadline: 2:00:00pm Local Time in Clarence-Rockland Ontario, Canada on
24-Mar-17

THE INFORMATION CONTAINED IN THIS DOCUMENT IS TIME SENSITIVE

Please note: This addendum is to be considered part of the above noted Request for Proposal as though included with the original version. This addendum does not affect the closing date/time: Bidders should acknowledge receipt of all Addendum / Addenda by inserting in the space provided on the Bid Submission Form, the numbers of all Addendum / Addenda received during the bidding period.

QUESTION REQUESTING CLARIFICATION

The following questions were received:

1	Question:	Have a geotechnical investigation, environmental assessment and topographic survey been completed for the Rockland site (adjacent to the existing fire hall)?
	Reply:	Only an environmental assessment of the property has been done at this stage
2	Question:	Did the recent demolition work at the Rockland site (adjacent to the existing fire hall) include the clean-up of any contaminated zones that may have been identified in the Phase 2 ESA? Following the demolition, are there inspection reports to prove the site is clean? Are there compaction reports for the backfill of the previous foundations and basement?
	Reply:	The cleanup of the contaminated soils will be completed at spring time by the municipality and is not part of this RFP. The two foundations were partially backfilled with material on site. The slopes have been cut around the two holes to make the site safer. No compaction has been provided for that work.